



कार्यालय अधिशासी अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण), अयोध्या

1/13/19/21ए, नैय्यर कालोनी, सिविल लाइन, अयोध्या

Email Id: eeupjn_cdfaizabad@yahoo.co.in

पत्रांक 372 / W-5 / 18

दिनांक 26/02/2024

सेवा में,
डायमण्ड एकेडमी,
रामपुर भगन,
अयोध्या।

विषय : जल परीक्षण रिपोर्ट प्रेषित किये जाने के संबंध में।

महोदय,

उपरोक्त विषयक आपके कार्यालय पत्रांक 0 दिनांक 20.02.2024 द्वारा प्राप्त जनपद अयोध्या के रामपुर भगन स्थित डायमण्ड एकेडमी विद्यालय से प्राप्त नलकूप के जल नमूने का रासायनिक परीक्षणोपरान्त जल परीक्षण रिपोर्ट एवं मनी रसीद संख्या...32९1... दिनांक 26/02/2024 संलग्न कर प्रेषित है।

संलग्नक- जल परीक्षण रिपोर्ट 1 नग
मनी रसीद सं० ...32९1...

भवदीय

(अरविन्द यादव)
अधिशासी अभियन्ता

Water Analysis Report



District Level Water Analysis Laboratory

Office of the Executive Engineer Khand Karyalaya
U. P. Jal Nigam (Rural), 1/13/19/21A, Nayyar Colony, Civil
Line, Ayodhya- 224001

Report No.: UPJN/AYO/Feb/24/05		Date: 20.02.2024	No. of Pages: 1
Customer Details			
Office Name and Address		Diamond Academy, Rampur Bhagan Ayodhya	
Ref. Letter No. & Date		0	Date: 20.02.2024
Basic Details of Sample			
District	Ayodhya	Block	Bikapur
Gram Panchayat	Rampur Bhagan	Village	Rampur Bhagan
Habitation	Rampur Bhagan	Location	Rampur Bhagan
Water Source	Tubewell(submersible)	Sample Code	UPJN/AYO/Feb/24/05
Quantity of Sample	1000 mL (Normal)	Sampling date	20.02.2024
Sample Received Date	20.02.2024	S. collected by	Virendra Kumar Gupta
Sampling Method Used	NA	Sample Depositor	Virendra Kumar Gupta
Analysis Start Date	20.02.2024	Analysis Completion Date: 20.02.2024	

S. No.	Analysed Parameters	Observed Value	Specification as per IS 10500:2012 (Second Revision)		Ref. Methods of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH @ 24.6 °C	7.24	6.5-8.5	6.5-8.5	IS 3025 (Part 11): 2022, Electrometric Method
2	Turbidity (NTU)	0.00	1	5	IS 3025 (Part 10): 1984 (Nephelometric method)
3	Total Dissolved Solids, mg/l	270.00	500	2000	IS 3025 (Part 16): 1984, Gravimetric method
4	Chloride (as Cl), mg/l	24.00	250	1000	IS 3025 (Part 32): 1988, Argentometric method
5	Total Alkalinity, (as CaCO ₃) mg/l	256.00	200	600	IS 3025 (Part 23):1986 (Indicator method)
6	Total Hardness, (as CaCO ₃) mg/l	238.00	200	600	IS 3025 (Part 21): 2009, EDTA method
7	Sulphate (as SO ₄), mg/l	5.64	200	400	APHA 23rd Edition -4500-SO ₄ Method E (Turbidimetric Method)
8	Fluoride (as F), mg/l	0.44	1.0	1.5	APHA 23rd Edition -4500-F Method C (Ion-Selective Electrode Method)
9	Iron (as Fe), mg/l	0.08	1.0	No relaxation	APHA 23rd Edition -3500-Fe Method B (Phenanthroline Method)
10	Nitrate (as NO ₃), mg/l	3.56	45.00	No relaxation	APHA 23rd Edition -4500- NO ₃ Method B (UV Screening Method)

All These parameters are under NABL Scope, BDL-Below Detection Limit, NA- Not Analysed

Note: 1. This certificate refers only to the particular sample(s) submitted for analysis.

2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.

3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements.

4. Sample(s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified.

5. Parameters above Permissible Limit are written in bold.

6. Sample(s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available.

7. Sample is Collected by Lab

Satish Kumar
SATISH KUMAR
(Report Prepared by)

Alok Kumar
ALOK KUMAR
(Report Authorized by)
जनपदीय प्रयोगशाखा

Laboratory Contact detail:

Email: upjn:uralayodhya@gmail.com

उपप्रजल निगम (ग्रामीण)

*****END OF THE ANALYSIS REPORT*****
अयोध्या

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

पत्रांक 372 / W-5 / 18

दिनांक 26/02/2024


No. UPJN/AYO/Feb/24/05

Dated :20.02.2024

It is certified that an inspection team headed by Mr. Alok Kumar (Chemist) Name of Officer with Designation) From Division Office , U.P. Jal Nigam (RURAL) Ayodhya (Name of Department/ Office) inspected the Diamond Academy, Rampur Bhagan Ayodhya (Name & Address of the School) on 20.02.2024 (Date of Inspection) and on the basis of Water test Report (Attached) bearing No JPJN/AYO/Feb/24/05 dated 20.02.2024 of Office of the Executive Engineer Khand Karyalaya U.P. Jal Nigam (Rural), 1/13/19/21A, Nayar Colony, Civil Line, Ayodhya-224001 (PHED Lab) certified that the Diamond Academy (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Signature with Seal :


सहायक अभियन्ता
निर्माण खण्ड
उ०प्र० जल निगम (ग्रामीण)
अयोध्या

Name : Ashvini Yadav


Designation : Assistant Engineer

Name & Address of the office / Department:
Division Office , U.P. Jal Nigam (RURAL) Ayodhya

Diamond Academy,

Rampur Bhagan Ayodhya.

Name & Address of the Institution)


कोमिस्ट
जनपदीय प्रयोगशाखा
उ०प्र० जल निगम (ग्रामीण)
अयोध्या