



कार्यालय अधिशासी अभियन्ता, खण्ड कार्यालय, उ०प्र० जल निगम (ग्रामीण), अयोध्या

1/13/107, नैय्यर कालोनी, सिविल लाइन्स, अयोध्या-224001

पत्रांक

5579

/

W-5

/ 76

दिनांक 31/12/24

सेवा में,

प्रधानाचार्य,
डायमण्ड एकेडमी,
रामपुर भगन,
अयोध्या।

महोदय,

उपरोक्त विषयक आपके कार्यालय पत्रांक संख्या 0 दिनांक 29/12/2025 द्वारा प्राप्त जनपद अयोध्या के रामपुर भगन स्थित डायमण्ड एकेडमी से प्राप्त जल स्रोत के जल नमूने का रासायनिक परीक्षणोपरान्त जल परीक्षण रिपोर्ट एवं मनी रसीद संख्या 65533, दिनांक 30/12/2025, संलग्न कर प्रेषित है।

संलग्नक- जल परीक्षण रिपोर्ट- 1 नग

मनी रसीद संख्या 65533

भवदीय

(अरविन्द यादव)
अधिशासी अभियन्ता

MANAGER
DIAMOND ACADEMY
RAMPUR BHAGAN AYODHYA

PRINCIPAL
DIAMOND ACADEMY
RAMPUR BHAGAN AYODHYA

Water Analysis Report



District Level Water Analysis Laboratory
Office of the Executive Engineer Khand karyalay, U.P. Jal Nigam
(Rural) Gata NO- 57 Mi. Manjha Jamthara, (In campus 33 MLD S.T.P.)



URL NO-TC-16371250000004F				Page No-1		
Report No-02	Chemical Test/UPIN/Ayo/Dec/25/02	Date	31-12-2025	S.No-04	SAMPLE CODE	UPIN/Ayo/Dec/25/02
Customer Details- Dimond Academy Rampur Bhagan, Ayodhya (224203)						
Office Name and Address		Dimond Academy Rampur Bhagan, Ayodhya				
Ref. Letter No. & Date		0				
Basic Details of sample						
District	Ayodhya	Block	Bikapur			
Gram Panchayat	Rampur Bhagan	Village	Rampur Bhagan			
Habitation	Rampur Bhagan	Location	Dimond Academy Rampur Bhagan, Ayodhya			
Water Source	Handpump	Sample Code	UPIN/Ayo/Dec/25/02			
Quantity of sample	1 Litre	Sampling Date	29-12-2025			
Sample Received Date	29-12-2025	S. Collected By	Parbhat Partel			
Sampling Method Used	Sample Submitted by Customer	Sample Depositor	Parbhat Partel			
Analysis Start Date	29-12-2025	Analysis Completion Date	30-12-2025			
Environment Condition						
Temperature	25±3 °C	Relative Humidity	50%±15%			
S.No.	Analysed Parameters	Unit of Measurement	Observed Value	Specified Values as		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit in absence of alternate source	
1	2	3	4	5	6	7
1	Odour	NA	Agreeable	Agreeable	Agreeable	IS 3025 (Part 5): 2018
2	Taste	NA	Agreeable	Agreeable	Agreeable	IS 3025 (Part 8):2017
3	PH	NA	7.20	6.5-8.5	6.5-8.5	IS 3025 (Part 11):2022 Electrometric Method
4	Colour (Hazen units)	HU	3	5	15	APHA 24rd Edition -2120- Colour Method B (Platinum Cobalt Visual Comparison): 2023
5	Turbidity (NTU)	NTU	0.22	1	5	IS 3025 (Part 10):2023 (Nephelometric method)
6	Total Dissolved Solids	mg/l	288	500	2000	IS 3025 (Part 16):2023(Gravimetric method)
7	Chloride (as Cl)	mg/l	33.98	250	1000	IS 3025 (Part 32):2019(Argentometric method)
8	Total Alkalinity, (as CaCO ₃)	mg/l	210	200	600	IS 3025 (Part 23):2023 (Potentiometric Method and Indicator method)
9	Total Hardness, (as CaCO ₃)	mg/l	212	200	600	IS 3025 (Part 21):2019(EDTA Titrimetric method)
10	Calcium (as Ca)	mg/l	52.10	75	200	IS 3025 (Part 40):2019 (EDTA Titrimetric method)
11	Magnesium (as Mg)	mg/l	19.68	30	100	IS 3025 (Part 46):2023(Volumetric method)
12	Sulphate (as SO ₄)	mg/l	1.80	200	400	APHA 24rd Edition -4500-SO ₄ Method E (Turbidimetric Method):2023
13	Nitrate (as NO ₃)	mg/l	1.20	45	No relaxation	APHA 24rd Edition -4500-NO ₃ Method B (UV Screening Method):2023
14	Flouride (as F)	mg/l	0.17	1.0	1.5	APHA 24rd Edition -4500-F Method C (Electrode Method):2023
15	Iron (as Fe)	mg/l	0.12	1.0	No relaxation	APHA 24rd Edition -3500-Fe Method B (Phenanthroline Method):2023
All These parameters are under NABL Scope, BDL-Below Detection Limit, NA-Not Analysed						
Note: 1. This certificate refers only to the particular sample (s) submitted for analysis. 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory. 3. The analysis results reported in this certificate are valid at the time of and under the stated conditions of measurements. 4. Sample (s) will be stored up to 07 days (in case of non-perishable items only) from the date of issue of analysis reports, unless otherwise specified. 5. Parameters above Permissible Limit are written in bold. 6. Sample (s) with any parameter value above Accepted Limit will only be used for oral consumption, if no other source is available 7. Sample is not Collected by Lab.						
Satish Kumar (Report Prepared by)			Alok Kumar (Report Authorized by)			
Laboratory contact detail:			Email:upjnrruralayodhya@gmail.com			

*****END OF THE ANALYSIS REPORT*****

MANAGER
DIAMOND ACADEMY
RAMPUR BHAGAN AYODHYA

PRINCIPAL
DIAMOND ACADEMY
RAMPUR BHAGAN AYODHYA

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE

No. UPJN/Ayo/Dec/25/02

Dated : 30.12.2025

It is certified that an inspection team headed by **Mr. Alok Kumar (Chemist)** Name of Officer with Designation) From **Division Office , U.P. Jal Nigam (RURAL) Ayodhya** (Name of Department/ Office) inspected the **Diamond Academy, Rampur Bhagan, Ayodhya (224203)**. (Name & Address of the School) on **30.12.2025** (Date of Inspection) and on the basis of Water test Report (Attached) bearing No **UPJN/Ayo/Dec/25/02** dated **31.12.2025** of **Office of the Executive Engineer Khand Karyalaya U. P. Jal Nigam (Rural), 1/13/107, Nayar Colony, Civil Lines , Ayodhya- (224001)** (PHED Lab) certified that the **Diamond Academy** (Name of the School) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Signature with Seal :



निमाण मण्डल

Name: **Ashvani Kumar**

अयोग्यता


Designation : **Assistant Engineer**

Name & Address of the office /
Department: **Division Office , U.P. Jal Nigam (RURAL) Ayodhya**

To,

Diamond Academy,**Rampur Bhagan, Ayodhya (224203).**

(Name & Address of the Instituion)




केमिस्ट

जल उपयोग शाखा

उपप्रान्त निगम (ग्रामीण)

अयोध्या


MANAGER
DIAMOND ACADEMY
RAMPUR BHAGAN AYODHYA


PRINCIPAL
DIAMOND ACADEMY
RAMPUR BHAGAN AYODHYA